

Residential Smart Thermostat Qualified Products List

Updated 6/25/19

Approved Qualified Products:

Manufacturer	Model
ecobee	ecobee 3, ecobee 4, ecobee Smart Thermostat with Voice Control (NOT ecobee Lite)
Nest	Nest 3 rd Generation, NestE
Carrier	Cor – TP-WEM01-A
Bryant	T6-WEM01-A

BPA Smart Thermostat Specification:

In order for products to meet the standards of the qualified products list, they must have, at a minimum, the following:

- Independent of manufacturer evaluation(s) demonstrating energy savings for smart thermostat or ENERGY STAR certification and additional information necessary to prove energy savings

AND also have (in addition to evaluation or ENERGY STAR certification)

- 7-day programmable or learning-based scheduling
- Wi-Fi enabled, with remote access
- Built in occupancy sensor
- Heat pump auxiliary heat control and optimization



Smart Thermostat Project Information Form



For Single Family, Multifamily and Manufactured Home Residential Customers

Instructions: Complete this form and submit it to the serving electric utility.

HOUSEHOLD INFORMATION

Customer Name	Installation Address (Street, City, State, Zip)
Customer Phone	Installation Date:

EXISTING EQUIPMENT INFORMATION

One Smart Thermostat per furnace or heat pump controlled with a limit of two per household.

Existing Equipment Information	Thermostat 1	Thermostat 2
What heating system is the thermostat controlling?	<input type="checkbox"/> Electric Forced Air Furnace <input type="checkbox"/> Air or Ground Source Heat Pump	<input type="checkbox"/> Electric Forced Air Furnace <input type="checkbox"/> Air or Water Source Heat Pump

NEW EQUIPMENT INFORMATION

Information	Thermostat 1	Thermostat 2
Thermostat manufacturer		
Thermostat model		
Thermostat serial number		
Who installed the thermostat?	<input type="checkbox"/> Homeowner <input type="checkbox"/> Contractor or Utility	<input type="checkbox"/> Homeowner <input type="checkbox"/> Contractor or Utility

The installed thermostat must:

1. Be on the BPA Smart Thermostat Qualified Products List (www.bpa.gov/EE/Policy/IManual/Pages/IM-Document-Library.aspx)
2. Have occupancy detection set to on, and
3. If the thermostat controls a heat pump, be programmed to control a heat pump